



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.: IND/WB/FES/20182019/26853

Date: 21.08.2022

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Delhi World Public School, formerly Ideal School, under Ideal Science & Research Welfare Hub, Kalyani.
Ideal Science and Research Welfare Hub Campus, Kalyani Silpanchal, Plot no. S2 to S6, Phase-II, ward no. 14,
under Kalyani Municipality, P.O Kalyani, P.S Kalyani, Dist. Nadia, Pin - 741235.

Sub: Renewal Of Fire Safety Certificate for the occupancy of an existing G+III storied under group Educational Building in the name of Delhi World Public School (formerly known as Ideal School), under Ideal Science & Research Welfare Hub at plot no. S2 to S6, Phase- II, ward no. 14, under Kalyani Municipality, P.O.+P.S. Kalyani, Kalyani Shilpanchal, Dist – Nadia, Pin – 741235.

This is in reference to your application no. 0125191221000105 dated 08-07-2022 regarding the Renewal Of Fire Safety Certificate for the occupancy of an existing G+III storied under group Educational Building in the name of Delhi World Public School (formerly known as Ideal School), under Ideal Science & Research Welfare Hub at plot no. S2 to S6, Phase-II, ward no. 14, under Kalyani Municipality, P.O.+P.S. Kalyani, Kalyani Shilpanchal, Dist – Nadia, Pin – 741235.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated:-

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. One no another Fire Pump in the same capacity of existing Main Fire Pump as Stand By Pump shall have to be provide

& linkup with D.G. set.

3. Entrance/Exit gate must be free from the any type of obstruction.
4. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
5. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
6. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
7. A dedicated room including a C.C.T.V. shall have to be maintained, which will observe & alert all floors of the building.
8. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
9. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to be operate in the event of Fire and Testing.
10. Mock Fire practice and Evacuation Drill shall be performed periodically by the teachers, security staff and participants of all the occupants of the building.
11. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
12. Electrical safety audit to be conducted at a regular interval.
13. Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
14. First-Aid Fire Fighting system shall be provided as per I.S. specification.
15. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
16. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
17. Periodical flashing of water from the roof at top most landing valve pipe line point shall be made to maintain the efficient working performance of above mentioned system.
18. The management of the organization/building as the case may be shall maintain the Fire Prevention & Fire Safety measures in good repair and efficient condition at all time which are installed in the said educational building for the use at the time of the Fire or other Emergencies.

This Renewal Of Fire Safety Certificate is valid for 3 (Three) year and have to be renewed every 3 (Three) year from the date of issue of this letter. Each after 3 (Three) year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the Life and Fire Safety arrangements and installation of the said School Building.

Signature valid

Digitally signed by SAROJ
KUMAR BARI
Date: 2022.05.11 20:52:36 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20182019/2685