



**Government of West Bengal**  
**Office of the Director General**  
**West Bengal Fire & Emergency Services**  
**13D, Mirza Ghalib Street, Kolkata – 16**

**Memo No.: FSR/IND/WB/FES/20182019/26853**

**Date : 12-11-2025**

**From :**  
**Divisional Fire Officer**  
**Fire Prevention Wing,**  
**West Bengal Fire & Emergency Services**

**To :**  
**Delhi World Public School, formerly Ideal School, under Ideal Science & Research Welfare Hub, Kalyani. Ideal Science and Research Welfare Hub Campus**  
**Kalyani Silpanchal, Plot no. S2 to S6, Phase-II, ward no. 14, under Kalyani Municipality, P.O Kalyani, P.S Kalyani, Dist. Nadia, Pin-741235**

**Sub : Conditional Renewal of Fire Safety Certificate for an existing construction of Ground+III Storied School building under Principal Group Occupancy "Educational" in the name and style of "Ideal School", Delhi World public school under Ideal Science & Research Welfare Hub Companies", at Holding No.- P/N- S2 to S6, Phase-II, Ward No.-14, Kalyani Shilpanchal, Kalyani, Nadia, W.B, India.**

This is in reference to your AIN 211912506300006558 dated 15-Jul-2025 regarding Conditional Renewal of Fire Safety Certificate for an existing construction of Ground+III Storied School building under Principal Group Occupancy "Educational" in the name and style of "Ideal School", Delhi World public school under Ideal Science & Research Welfare Hub Companies", at Holding No.- P/N- S2 to S6, Phase-II, Ward No.-14, Kalyani Shilpanchal, Kalyani, Nadia, W.B, India..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

**However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.**

**Recommendation:**



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300006558

STANDBY FIRE PUMP TO BE INSTALLED.

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Building shall not be used for the storage of any hazardous materials i.e., Volatile flammable liquids. If stored then, it shall be restricted to science laboratories only.
3. Rooms used by the preschool, Grade-1 students shall be located on ground floor of exit discharge. Room occupied by class II students shall be located not above one floor higher than ground floor of exit discharge.
4. To eliminate risk of Fire Hazards, Good House Keeping shall be strictly maintained.
5. Switch Gear, Generator room, Electrical Panel Rooms shall have to be protected by suitable CO-2 or DCP Modular Fire Extinguisher Conforming I. S. Specification.
6. A Fire Control Room including Closed Circuit Television System and Public Address System will have to maintain to monitoring the entire educational Building.
7. The notice of Fire Fighting and Evacuation shall be displayed at all venerable places of the building.
8. The Teaching and Non-Teaching, employees and Security staff shall be conversant with installed fixed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
9. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. A crew of trained Fireman shall be maintained round the clock for safety of the building.
11. First-Aid-Fire Fighting system shall be provided as per I.S. Specification.
12. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
13. Electrical Audit shall be conducted by Government approved licence holder Supervisor and certificate must be submitted in the office at the time of renewal of Fire Safety Certificate.
14. Fire License for licensable articles shall be obtain from The Competent Authority, WBFES.
15. The Fire Safety Certificate is valid for three years from the date of the issue of this letter and has to be renewed within validity range.
16. The certificate is to be obtained from the Director General, West Bengal Fire and Emergency

Valid Upto : 10-Nov-2028

Memo No :  
FSB/IND/WB/FES/20182019/26853



Signature valid

Digitally Signed.  
Name: NIHAR RANJAN ROY  
Date: 12-Nov-2023 15:08:25  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300006558